

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

THMs REPORT

EPA Method 524.2

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/5/2013

Report Number: LC-W1302085-001

SAMPLE INFORMATION

Sample Number: 1302085-001

Customer Sample Number:

Location: 1H-9 EASTERN HIGH SCHOOL, 1700
EAST CAPITOL ST NE Type: Dist.
DBPR

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
2/12/2013	8:53	BS	2/12/2013 3:15:04 PM	BSmith

Parameter	MCL	MDL	RDL	Result	Analysis Date	Analyst
Chloroform	mg/L	0.03 ug/L	0.0005 mg/L	0.0137 mg/L	2/15/2013	RHoffa
Bromodichloromethane	mg/L	0.02 ug/L	0.0005 mg/L	0.0058 mg/L	2/15/2013	RHoffa
Dibromochloromethane	mg/L	0.03 ug/L	0.0005 mg/L	0.0011 mg/L	2/15/2013	RHoffa
Bromoform	mg/L	0.06 ug/L	0.0005 mg/L	ND mg/L	2/15/2013	RHoffa
Total THMs	0.080 mg/L	0.06 ug/L	0.001 mg/L	0.021 mg/L	2/15/2013	RHoffa

Comment:

ND = Non-Detect

MCL = Maximum Contaminant Level

MDL = Method Detection Limit

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

THMs REPORT

EPA Method 524.2

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/5/2013

Report Number: LC-W1302085-003

SAMPLE INFORMATION

Sample Number: 1302085-003

Customer Sample Number:

Location: 2H-1 BKJV HOSPITAL FOR SICK CHILDREN,
1731 BUNKER HILL RD NE
DBPR

Type: Dist.

Collection Date:
2/12/2013

Collection Time:
10:22

Sampler:
BS

Received Date and Time:
2/12/2013 3:15:04 PM

Received By:
BSmith

Parameter	MCL	MDL	RDL	Result	Analysis Date	Analyst
Chloroform	mg/L	0.03 ug/L	0.0005 mg/L	0.0120 mg/L	2/15/2013	RHoffa
Bromodichloromethane	mg/L	0.02 ug/L	0.0005 mg/L	0.0054 mg/L	2/15/2013	RHoffa
Dibromochloromethane	mg/L	0.03 ug/L	0.0005 mg/L	0.0010 mg/L	2/15/2013	RHoffa
Bromoform	mg/L	0.06 ug/L	0.0005 mg/L	ND mg/L	2/15/2013	RHoffa
Total THMs	0.080 mg/L	0.06 ug/L	0.001 mg/L	0.018 mg/L	2/15/2013	RHoffa

Comment:

ND = Non-Detect

MCL = Maximum Contaminant Level

MDL = Method Detection Limit

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

THMs REPORT

EPA Method 524.2

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/5/2013

Report Number: LC-W1302085-004

SAMPLE INFORMATION

Sample Number: 1302085-004

Customer Sample Number:

Location: 2H-8 DC PUBLIC LIBRARY, 1801 HAMLIN ST NE
DBPR Type: Dist.

Collection Date: 2/12/2013 Collection Time: 13:20 Sampler: BS Received Date and Time: 2/12/2013 3:15:04 PM Received By: BSmith

Parameter	MCL	MDL	RDL	Result	Analysis Date	Analyst
Chloroform	mg/L	0.03 ug/L	0.0005 mg/L	0.0135 mg/L	2/15/2013	RHoffa
Bromodichloromethane	mg/L	0.02 ug/L	0.0005 mg/L	0.0057 mg/L	2/15/2013	RHoffa
Dibromochloromethane	mg/L	0.03 ug/L	0.0005 mg/L	0.0010 mg/L	2/15/2013	RHoffa
Bromoform	mg/L	0.06 ug/L	0.0005 mg/L	ND mg/L	2/15/2013	RHoffa
Total THMs	0.080 mg/L	0.06 ug/L	0.001 mg/L	0.020 mg/L	2/15/2013	RHoffa

Comment:

ND = Non-Detect

MCL = Maximum Contaminant Level

MDL = Method Detection Limit

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

THMs REPORT

EPA Method 524.2

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/5/2013

Report Number: LC-W1302085-006

SAMPLE INFORMATION

Sample Number: 1302085-006

Customer Sample Number:

Location: 3H-13 MIDTOWN BARBERSHOP 120
KENNEDY ST NW
DBPR

Type: Dist.

Collection Date:
2/12/2013

Collection Time:
12:44

Sampler:
BS

Received Date and Time:
2/12/2013 3:15:04 PM

Received By:
BSmith

Parameter	MCL	MDL	RDL	Result	Analysis Date	Analyst
Chloroform	mg/L	0.03 ug/L	0.0005 mg/L	0.0068 mg/L	2/15/2013	RHoffa
Bromodichloromethane	mg/L	0.02 ug/L	0.0005 mg/L	0.0052 mg/L	2/15/2013	RHoffa
Dibromochloromethane	mg/L	0.03 ug/L	0.0005 mg/L	0.0016 mg/L	2/15/2013	RHoffa
Bromoform	mg/L	0.06 ug/L	0.0005 mg/L	ND mg/L	2/15/2013	RHoffa
Total THMs	0.080 mg/L	0.06 ug/L	0.001 mg/L	0.014 mg/L	2/15/2013	RHoffa

Comment:

ND = Non-Detect

MCL = Maximum Contaminant Level

MDL = Method Detection Limit

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

THMs REPORT

EPA Method 524.2

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/5/2013

Report Number: LC-W1302085-008

SAMPLE INFORMATION

Sample Number: 1302085-008

Customer Sample Number:

Location: A1H-3 BKJV REFUGE TEMPLE CHURCH 420 56
STNE
DBPR

Type: Dist.

Collection Date:
2/12/2013

Collection Time:
11:55

Sampler:
BS

Received Date and Time:
2/12/2013 3:15:04 PM

Received By:
BSmith

Parameter	MCL	MDL	RDL	Result	Analysis Date	Analyst
Chloroform	mg/L	0.03 ug/L	0.0005 mg/L	0.0137 mg/L	2/15/2013	RHoffa
Bromodichloromethane	mg/L	0.02 ug/L	0.0005 mg/L	0.0056 mg/L	2/15/2013	RHoffa
Dibromochloromethane	mg/L	0.03 ug/L	0.0005 mg/L	0.0010 mg/L	2/15/2013	RHoffa
Bromoform	mg/L	0.06 ug/L	0.0005 mg/L	ND mg/L	2/15/2013	RHoffa
Total THMs	0.080 mg/L	0.06 ug/L	0.001 mg/L	0.020 mg/L	2/15/2013	RHoffa

Comment:

ND = Non-Detect

MCL = Maximum Contaminant Level

MDL = Method Detection Limit

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

THMs REPORT

EPA Method 524.2

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/5/2013

Report Number: LC-W1302085-009

SAMPLE INFORMATION

Sample Number: 1302085-009

Customer Sample Number:

Location: L-4 HARBOR POLICE STATION, 550
WATER ST SW Type: Dist.
DBPR

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
2/12/2013	7:59	BS	2/12/2013 3:15:04 PM	BSmith

Parameter	MCL	MDL	RDL	Result	Analysis Date	Analyst
Chloroform	mg/L	0.03 ug/L	0.0005 mg/L	0.0126 mg/L	2/15/2013	RHoffa
Bromodichloromethane	mg/L	0.02 ug/L	0.0005 mg/L	0.0055 mg/L	2/15/2013	RHoffa
Dibromochloromethane	mg/L	0.03 ug/L	0.0005 mg/L	0.0010 mg/L	2/15/2013	RHoffa
Bromoform	mg/L	0.06 ug/L	0.0005 mg/L	ND mg/L	2/15/2013	RHoffa
Total THMs	0.080 mg/L	0.06 ug/L	0.001 mg/L	0.019 mg/L	2/15/2013	RHoffa

Comment:

ND = Non-Detect

MCL = Maximum Contaminant Level

MDL = Method Detection Limit

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

THMs REPORT

EPA Method 524.2

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/5/2013

Report Number: LC-W1302085-011

SAMPLE INFORMATION

Sample Number: 1302085-011

Customer Sample Number:

Location: FIELD BLANK
DBPR

Type: SP

Collection Date:
2/12/2013

Collection Time:
6:44

Sampler:
BS

Received Date and Time:
2/12/2013 3:15:04 PM

Received By:
BSmith

Parameter	MCL	MDL	RDL	Result	Analysis Date	Analyst
Chloroform	mg/L	0.03 ug/L	0.0005 mg/L	ND mg/L	2/15/2013	RHoffa
Bromodichloromethane	mg/L	0.02 ug/L	0.0005 mg/L	ND mg/L	2/15/2013	RHoffa
Dibromochloromethane	mg/L	0.03 ug/L	0.0005 mg/L	ND mg/L	2/15/2013	RHoffa
Bromoform	mg/L	0.06 ug/L	0.0005 mg/L	ND mg/L	2/15/2013	RHoffa
Total THMs	0.080 mg/L	0.06 ug/L	0.001 mg/L	ND mg/L	2/15/2013	RHoffa

Comment:

ND = Non-Detect

MCL = Maximum Contaminant Level

MDL = Method Detection Limit

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

THMs REPORT

EPA Method 524.2

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/5/2013

Report Number: LC-W1302105-001

SAMPLE INFORMATION

Sample Number: 1302105-001

Customer Sample Number:

Location: 1H-10 ANNE M. GODING SCHOOL, 900 F ST NE
DBPR Type: Dist.

Collection Date: 2/13/2013 Collection Time: 9:50 Sampler: BS Received Date and Time: 2/13/2013 2:59:15 PM Received By: BSmith

Parameter	MCL	MDL	RDL	Result	Analysis Date	Analyst
Chloroform	mg/L	0.03 ug/L	0.0005 mg/L	0.0114 mg/L	2/14/2013	RHoffa
Bromodichloromethane	mg/L	0.02 ug/L	0.0005 mg/L	0.0056 mg/L	2/14/2013	RHoffa
Dibromochloromethane	mg/L	0.03 ug/L	0.0005 mg/L	0.0011 mg/L	2/14/2013	RHoffa
Bromoform	mg/L	0.06 ug/L	0.0005 mg/L	ND mg/L	2/14/2013	RHoffa
Total THMs	0.080 mg/L	0.06 ug/L	0.001 mg/L	0.018 mg/L	2/14/2013	RHoffa

Comment:

ND = Non-Detect

MCL = Maximum Contaminant Level

MDL = Method Detection Limit

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

THMs REPORT

EPA Method 524.2

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/5/2013

Report Number: LC-W1302105-003

SAMPLE INFORMATION

Sample Number: 1302105-003

Customer Sample Number:

Location: 3H-4 BKJV LOWELL SCHOOL, 1640 KALMIA
RD NW Type: Dist.
DBPR

Collection Date: 2/13/2013 Collection Time: 13:39 Sampler: BS Received Date and Time: 2/13/2013 2:59:15 PM Received By: BSmith

Parameter	MCL	MDL	RDL	Result	Analysis Date	Analyst
Chloroform	mg/L	0.03 ug/L	0.0005 mg/L	0.0085 mg/L	2/14/2013	RHoffa
Bromodichloromethane	mg/L	0.02 ug/L	0.0005 mg/L	0.0060 mg/L	2/14/2013	RHoffa
Dibromochloromethane	mg/L	0.03 ug/L	0.0005 mg/L	0.0016 mg/L	2/14/2013	RHoffa
Bromoform	mg/L	0.06 ug/L	0.0005 mg/L	ND mg/L	2/14/2013	RHoffa
Total THMs	0.080 mg/L	0.06 ug/L	0.001 mg/L	0.016 mg/L	2/14/2013	RHoffa

Comment:

ND = Non-Detect

MCL = Maximum Contaminant Level

MDL = Method Detection Limit

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

THMs REPORT

EPA Method 524.2

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/5/2013

Report Number: LC-W1302105-004

SAMPLE INFORMATION

Sample Number: 1302105-004

Customer Sample Number:

Location: 4H-3 LAFAYETTE ELEM SCHOOL, 5701
BROAD BRANCH ROAD NW Type: Dist.
DBPR

Collection Date:
2/13/2013

Collection Time:
7:41

Sampler:
BS

Received Date and Time:
2/13/2013 2:59:15 PM

Received By:
BSmith

Parameter	MCL	MDL	RDL	Result	Analysis Date	Analyst
Chloroform	mg/L	0.03 ug/L	0.0005 mg/L	0.0076 mg/L	2/14/2013	RHoffa
Bromodichloromethane	mg/L	0.02 ug/L	0.0005 mg/L	0.0055 mg/L	2/14/2013	RHoffa
Dibromochloromethane	mg/L	0.03 ug/L	0.0005 mg/L	0.0016 mg/L	2/14/2013	RHoffa
Bromoform	mg/L	0.06 ug/L	0.0005 mg/L	ND mg/L	2/14/2013	RHoffa
Total THMs	0.080 mg/L	0.06 ug/L	0.001 mg/L	0.015 mg/L	2/14/2013	RHoffa

Comment:

ND = Non-Detect

MCL = Maximum Contaminant Level

MDL = Method Detection Limit

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

THMs REPORT

EPA Method 524.2

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/5/2013

Report Number: LC-W1302105-005

SAMPLE INFORMATION

Sample Number: 1302105-005

Customer Sample Number:

Location: A1H-8 MY 3 SONS BARBER SHOP, 3125
DBPR MLK AVE SE Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
2/13/2013	11:58	BS	2/13/2013 2:59:15 PM	BSmith

Parameter	MCL	MDL	RDL	Result	Analysis Date	Analyst
Chloroform	mg/L	0.03 ug/L	0.0005 mg/L	0.0132 mg/L	2/14/2013	RHoffa
Bromodichloromethane	mg/L	0.02 ug/L	0.0005 mg/L	0.0059 mg/L	2/14/2013	RHoffa
Dibromochloromethane	mg/L	0.03 ug/L	0.0005 mg/L	0.0012 mg/L	2/14/2013	RHoffa
Bromoform	mg/L	0.06 ug/L	0.0005 mg/L	ND mg/L	2/14/2013	RHoffa
Total THMs	0.080 mg/L	0.06 ug/L	0.001 mg/L	0.020 mg/L	2/14/2013	RHoffa

Comment:

ND = Non-Detect

MCL = Maximum Contaminant Level

MDL = Method Detection Limit

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

THMs REPORT

EPA Method 524.2

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/5/2013

Report Number: LC-W1302105-007

SAMPLE INFORMATION

Sample Number: 1302105-007

Customer Sample Number:

Location: L-1 BKJV RONALD BROWN MIDDLE
SCHOOL, 4800 MEADE ST NE
DBPR

Type: Dist.

Collection Date:
2/13/2013

Collection Time:
10:33

Sampler:
BS

Received Date and Time:
2/13/2013 2:59:15 PM

Received By:
BSmith

Parameter	MCL	MDL	RDL	Result	Analysis Date	Analyst
Chloroform	mg/L	0.03 ug/L	0.0005 mg/L	0.0132 mg/L	2/14/2013	RHoffa
Bromodichloromethane	mg/L	0.02 ug/L	0.0005 mg/L	0.0059 mg/L	2/14/2013	RHoffa
Dibromochloromethane	mg/L	0.03 ug/L	0.0005 mg/L	0.0012 mg/L	2/14/2013	RHoffa
Bromoform	mg/L	0.06 ug/L	0.0005 mg/L	ND mg/L	2/14/2013	RHoffa
Total THMs	0.080 mg/L	0.06 ug/L	0.001 mg/L	0.020 mg/L	2/14/2013	RHoffa

Comment:

ND = Non-Detect

MCL = Maximum Contaminant Level

MDL = Method Detection Limit

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

THMs REPORT

EPA Method 524.2

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/5/2013

Report Number: LC-W1302105-008

SAMPLE INFORMATION

Sample Number: 1302105-008

Customer Sample Number:

Location: L-12 BLUE PLAINS WASTEWATER TRTMT, 5000 OVERLOOK AVE SW
DBPR Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
2/13/2013	11:22	BS	2/13/2013 2:59:15 PM	BSmith

Parameter	MCL	MDL	RDL	Result	Analysis Date	Analyst
Chloroform	mg/L	0.03 ug/L	0.0005 mg/L	0.0149 mg/L	2/14/2013	RHoffa
Bromodichloromethane	mg/L	0.02 ug/L	0.0005 mg/L	0.0061 mg/L	2/14/2013	RHoffa
Dibromochloromethane	mg/L	0.03 ug/L	0.0005 mg/L	0.0011 mg/L	2/14/2013	RHoffa
Bromoform	mg/L	0.06 ug/L	0.0005 mg/L	ND mg/L	2/14/2013	RHoffa
Total THMs	0.080 mg/L	0.06 ug/L	0.001 mg/L	0.022 mg/L	2/14/2013	RHoffa

Comment:

ND = Non-Detect

MCL = Maximum Contaminant Level

MDL = Method Detection Limit

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/5/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

THMs REPORT

EPA Method 524.2

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/5/2013

Report Number: LC-W1302105-010

SAMPLE INFORMATION

Sample Number: 1302105-010

Customer Sample Number:

Location: FIELD BLANK
DBPR

Type: SP

Collection Date:
2/13/2013

Collection Time:
6:40

Sampler:
BS

Received Date and Time:
2/13/2013 2:59:15 PM

Received By:
BSmith

Parameter	MCL	MDL	RDL	Result	Analysis Date	Analyst
Chloroform	mg/L	0.03 ug/L	0.0005 mg/L	ND mg/L	2/14/2013	RHoffa
Bromodichloromethane	mg/L	0.02 ug/L	0.0005 mg/L	ND mg/L	2/14/2013	RHoffa
Dibromochloromethane	mg/L	0.03 ug/L	0.0005 mg/L	ND mg/L	2/14/2013	RHoffa
Bromoform	mg/L	0.06 ug/L	0.0005 mg/L	ND mg/L	2/14/2013	RHoffa
Total THMs	0.080 mg/L	0.06 ug/L	0.001 mg/L	ND mg/L	2/14/2013	RHoffa

Comment:

ND = Non-Detect

MCL = Maximum Contaminant Level

MDL = Method Detection Limit

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

3/5/2013

Date